

## Record of Water Well

Indiana Department of Natural Resources

<b>Reference Number</b>	<b>Driving directions to well</b>	<b>Date completed</b>
<b>180246</b>		Jan 13, 1977

<b>Owner-Contractor</b>	<b>Name</b>	<b>Address</b>	<b>Telephone</b>
Owner			
Driller	HAMILTON BROS INC.	PO BOX 24181, INDPLS IN	
Operator	ED RANDOLPH	License: null	
Company	PEDIGO & YOUNG		

**Construction Details**

Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth: 62.0	Pump setting depth:	Water quality:
Casing	Length: 59.0	Material:	Diameter: 4.0
Screen	Length: 3.0	Material:	Diameter: 4.0 Slot size: .060

Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 1.0 hrs.	BailTest rate: gpm for hrs.
	Drawdown: ft.	Static water level: ft.	Bailer Drawdown ft.

Grouting Information	Material:	Depth: from to
	Installation Method:	Number of bags used:

Well Abandonment	Sealing material:	Depth: from to
	Installation Method:	Number of bags used:

Administrative	County: MARION	Township: 15N Range: 3E
	Section: of Section 5	Topo map: INDIANAPOLIS WEST
	Grant Number:	
	Field located by:	on:
	Courthouse location by:	on:
	Location accepted w/o verification by: BRUNS	on: Feb 14, 1977
	Subdivision name:	Lot number:
	Ft W of EL:	Ft N of SL:
	Ft E of WL:	Ft S of NL:
	Ground elevation:	Bedrock elevation:
	Depth to bedrock:	Aquifer elevation:
	UTM Easting:	UTM Northing:

Well Log	Top	Bottom	Formation
	0.0	1.0	TOPSOIL & CLAY
	1.0	35.0	S&G
	35.0	62.0	BR CLAY

**Comments**